



Wicomico County Purchasing
125 N. Division St. Room B-3
Salisbury, MD 21801
Ph. 410-548-4805 Fax 410-334-3130

Date: 7/14/16

Addendum # 1

Bid: Internal Fiber Wiring at Civic Center

Wicomico County Youth and Civic Center's Interior Fiber Cabling Questions from the Pre-bid meeting held at 2:00 pm on July 8, 2016.

An 8-1/2"x11' copy of the First Floor Plan was handed out to all of the vendors in attendance.

- Q: 1) Specify what kind of jacketing or conduit material for the cabling?
Specify what kind of connectors does the county want?
- A: **Fiber optic cable running through conduit is not required. Use industry standard jacketing and installation methods. Fiber optic cable will need to be terminated with LC connectors.**
- Q: 2) All Equipment is to be wall-mounted in each location depicted on the Floor Plan.
What is the manufacturer and model number for the wall-mounted equipment?
- A: **Not specified, we prefer wall mounted termination box type.**
- Q: 3) Is the equipment going to be a "Box type" of a "Rack type"?
- A: **We prefer wall mounted termination box type.**
- Q: 4) Is the Fiber Cabling specified for a Single Mode or a Multi-mode?
- A: **Aqua color multimode (50/125) (850 nm) plenum rated.**
- Q: 5) How many wall penetrations are going to be needed through the CMU walls?
- A: **there will be fifteen (15) penetrations through CMU walls and six (6) penetrations through drywall walls.**

Addendum No. 1

Q: 6) It is assumed by the vendor that the ceilings will be removed/ demolished when they will be running the overhead cabling. Who is responsible for possible damages?

A: **If, at the time of the cabling installation occurs and new ceilings are in place, then any damages incurred would be the responsibility of the vendor.**

Q: 7) What type of Testing Method will be used after the cabling is complete?

A: **Testing for continuity and end-to-end loss**

Q: 8) Whom will be responsible for the cost of the testing?

A: **The vendor**

Q: 9) On the fiber run from the Office to Station 1, you are calling out for a 36 Strand Fiber. That fiber run is around 375 foot. Vendors only sell a minimum of 2,000 feet. Can we use one 24 strand and one 12 strand for this?

A: **This will be acceptable.**

The cut-off date for any further bidding questions is Friday, July 15, 2016 at 5pm.

Submitted by
Wicomico County Purchasing
purchasing@wicomicocounty.org