



Wicomico County Purchasing
125 N. Division St. Room B-3
Salisbury, MD 21801
Ph. 410-548-4805 Fax 410-334-3130
Email: purchasing@wicomicocounty.org

Addendum # 2 Parks Maintenance Complex Wetland

Date of Addendum: 3/3/17

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal deadline has been changed to Thursday, March 9, 2017 at 2:15 PM.

1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	Q. There is no line item for the concrete weir wall. Where should this be placed in our bid? A. This will be included in Item # 5 Concrete Forebay.
1.2	Q. When is the anticipated start date for this project? A. April.
1.3	Q. Is there any re-bar needed for this connection between the footer and the head wall? A. No. This will be a monolithic pour.
1.4	Q. Will geo-technical testing be needed for the concrete work? If so, will this be the responsibility of the contractor? A. As long as the concrete meets the specifications as noted on the plans.
1.5	Q. Will as-built certification be needed? A. Yes
1.6	Q. There is some confusion with the imbricated rock shown on page 4 of 6, Cross Section B-B' and F-F'. Can you give us some clarification as to the type of rock or what your intention is in the Parks Maintenance and Public Safety Facilities? A. The County's intentions are to have a 'sturdier' earthen berm by embedding class 0 riprap (just regular riprap, the kind you would use to fill gabion baskets or place at an outfall) into the earth, and then tamp additional dirt into all the cracks so it's smoother, and then planting with grass seed. Stabilization matting may be needed over the seeded area until the grass has a chance to fill in. The berm or weir needs to be stronger than earth alone, so embedding the rock into it should make it less susceptible to washing out.

END OF ADDENDUM