



Wicomico County Purchasing
125 N. Division St. Room B-3
Salisbury, MD 21801
Ph. 410-548-4805 Fax 410-334-3130
Email: purchasing@wicomicocounty.org

Addendum # 2 Public Safety Complex Wetland

Date of Addendum: 3/3/2017

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal deadline has been changed to Thursday, March 9, 2017 at 2:15 PM.

1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	Q. When is the anticipated start date for this project? A. April.
1.2	Q. Will the clay material need soil or proctor tests before getting installed? A. No.
1.3	Q. If cut material coming out of the project site is wet, will the mentioned waste facility/landfill still accept it? A. Yes.
1.4	Q. Is there any imbricated stone (boulders) needed for the imbricated rock weir? Or is all the stone being used in the imbricated weir class 0 riprap? A. This question has been answered.
1.5	Q. Will as-built certification be needed? A. Yes.
1.6	Q. In several places in the specifications it mentions sod and seed/mulch (which would usually indicate not sod). Is everything within the LOD to get sod mats? A. The contractor shall follow the planting schedule as shown on page 6 of 6 in drawings attached to the Bid Documents. On slopes greater than 4 to 1 sod is recommended. On slopes less than 4 to 1 seed and mulch is recommended.

END OF ADDENDUM