



Wicomico County Purchasing
 125 N. Division St. Room B-3
 Salisbury, MD 21801
 Ph. 410-548-4805 Fax 410-334-3130
 Email: purchasing@wicomicocounty.org

Addendum # 1 Hot Mix Asphalt Paving UMD Extension Parking Lot

Date of Addendum: 5/25/18

NOTICE TO ALL BIDDERS AND PLANHOLDERS
The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE
The bid submittal time has not been changed.

1.0 – ATTACHMENTS	
Item	Description
1.1	Pre-Bid Sign in sheet

2.0 – QUESTIONS AND ANSWERS	
The following questions and answers are provided as a matter of information to clarify issues raised about the Proposal Documents.	
Item	Questions and Answers
2.1	Q. Is striping to be included in either of these jobs? A. No
2.2	Q. Is a Bid Bond required? A. No
2.3	Q. Are performance and/or payment bonds required? A. No
2.4	Q. Is there a quantity of patch available so that all contractors are bidding the same quantity? A. No
2.5	Q. What is the depth of patch and what material will the patch require? A. To be determined by contractor
2.6	Q. What is the depth of handicap removal and what material will the handicap area require? A. Assume 3”
2.7	Q. Will topsoil & seeding be required along the edge of the new blacktop? A. No
2.8	Q. Can the contractor work more than 8 hours per day? A. Yes
2.9	Q. Will the parking lot be in use while the contractor works? A. No
2.10	Q. Can the lot be paved completely in one day or must the work be done in sections? A. Yes one day

2.11	<p>Q. Measurement and Payment section mention (milling by the square yard and paving overlay fabric by the square yard)</p> <p>A. Milling by SY, no paving fabric</p>
2.12	<p>Q. Will these prices be required before the bid or are they mentioned a possible contingency that will be negotiated at later date?</p> <p>A. Milling should be included in lump sum bid. Unforeseen conditions shall determine any changes to the original bid</p>
2.13	<p>Q. Please clarify TESTING requirements. It appears that testing is NOT required unless an agent of the County deems it necessary and the cost will be the responsibility of the Contractor?</p> <p>A. We will require the winning contractor to provide 4 borings at the Elections lot to determine the condition of the base material</p>
2.14	<p>Q. Please clarify the “patching of two entrances in preparation for paving” line item within the “Work Description” section of the specifications manual. Are we to remove the asphalt in its entirety and re-pave or wedge and level over the existing pavement to promote better drainage?</p> <p>A. The contractor is wedge and level to promote positive drainage</p>
2.15	<p>Q. Are we to ignore the “MEASUREMENT AND PAYMENT” section of the specifications manual? One item in this section calls for a pavement overlay fabric. It is confusing.</p> <p>A. Ignore measurement and payment, and there will be no Paving Fabric</p>

END OF ADDENDUM

