



Wicomico County Purchasing
 125 N. Division St. Room B-3
 Salisbury, MD 21801
 Ph. 410-548-4805 Fax 410-334-3130
 Email: purchasing@wicomicocounty.org

Addendum # 1 Wicomico County Circuit Court Second Floor Renovations

Date of Addendum: May 29, 2018

NOTICE TO ALL BIDDERS AND PLANHOLDERS
The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE
The bid submittal time has not been changed.

1.0 – QUESTIONS AND ANSWERS	
The following questions and answers are provided as a matter of information to clarify issues raised about the Proposal Documents.	
Item	Questions and Answers
1.1	Q. Alternate #4 calls for a 10 year warranty on mechanical equipment. Please clarify this is correct. I don't know of any manufacturer that offers a 10 year warranty. A. If a 10-year warranty is unavailable, Contractor shall identify and include the maximum warranty available.
1.2	Q. Please clarify that we need to clean the new duct that's being installed per section 233113-3.6. Most of the time we cover the ends to keep clean. A. All ductwork is to be cleaned at the conclusion of construction as described in section 233113 3.6 "Cleaning New Systems".
1.3	Q. Please clarify that we need to carry a 5 year warranty in the base bid for sections 233423 HVAC Power Ventilators, 233600 Air Terminal Units, 236426 Air Cooled Chiller and 237313 Air Handling Units? A. A 5 year warranty shall be included in the base bid for the listed mechanical equipment as stated in the Contract Documents.

END OF ADDENDUM