



Wicomico County Purchasing  
125 N. Division St. Room B-3  
Salisbury, MD 21801  
Ph. 410-548-4805 Fax 410-334-3130  
Email: [purchasing@wicomicocounty.org](mailto:purchasing@wicomicocounty.org)

## **Addendum # 1 Salt Shed Design/Build**

Date of Addendum: 1/10/19

### **NOTICE TO ALL BIDDERS AND PLANHOLDERS**

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

### **BID SUBMITTAL DEADLINE**

The bid submittal time has not been changed.

### **1.0 – QUESTIONS AND ANSWERS**

The following questions and answers are provided as a matter of information to clarify issues raised about the Proposal Documents.

<b>Item</b>	<b>Questions and Answers</b>
1.1	<p>Q. Who will be responsible for the site work? Bid Documents assume IV. C. 7. Foundation assumes 2,500 psf ground, if this is not attainable will a change order be needed?</p> <p>A. Site work performed by the County. If the existing soils can't attain the 2500psf a decision on the best solution will be made at that time with a change to the original scope a possibility.</p>
1.2	<p>Q. Will the floor of the building be asphalt? Who is responsible for the floor of the building?</p> <p>A. The floor of the building will be asphalt provided by the County</p>
1.3	<p>Q. Section IV. C. 8. B.i.-will option 1 be a continuous poured concrete wall 12' tall?</p> <p>A. The "T" footer shall be constructed according to the conceptual drawings provided and consistent with the Engineers specifications.</p>

**END OF ADDENDUM**