



Wicomico County Purchasing
125 N. Division St. Room B-3
Salisbury, MD 21801
Ph. 410-548-4805 Fax 410-334-3130
Email: purchasing@wicomicocounty.org

Addendum # 1 Flooring Replacement & Installation

Date of Addendum: 4/8/19

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	Q. 26 oz. carpet - There are no specifications for fiber, backing or other warranties. A. Please bid a "Solution Dyed Nylon" 26 oz. Commercial level loop carpet with edge ravel and tuft bind and zipper warranties.
1.2	Q. Luxury Plank Flooring – There's no specification for wear layer thickness. A. 20mm wear layer
1.3	Q. There is no specification for cove base thickness/gage. Cove base comes .080 gage and 1/8" gage. A. 1/8" vinyl cove base.
1.4	Q. VCT – There's no spec for tile size or thickness. A. 1/8" VCT 12"X12"
1.5	Q. Quarter Round/Shoe Molding. Please specify a size for this material. Such as 3/4" or 1/2" A. Both 3/4" and 1/2" will be used as required per job.

END OF ADDENDUM