



Wicomico County Purchasing
125 N. Division St. Room B-3
Salisbury, MD 21801
Ph. 410-548-4805 Fax 410-334-3130
Email: purchasing@wicomicocounty.org

Addendum # 2 Willards Park Pavilion Renovation

Date of Addendum: 9/23/2020

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	Q. How are we to install 4 x 8 T & G plywood on 4' trusses without adding more support beams? A. Section IV Bid Specifications F. Bid Alternate: Replace "top of the existing trusses" with "top of newly installed purlins" Then remove section a. by doing this the purlins would not be used.
1.2	Q. Per Section 4; Subsection Item 9 (As pasted below), we are to replace 9 rows of purlins, there are 18 there it must have been your intent to replace them all since you are replacing the metal roof in the base bid. Please confirm. A. There are 9 rows on each side and the Successful Vendor will need to replace all 18.
1.3	Q. Can you please clarify in contract documents Section 4; Summary Section C; Item D if you want to paint the trusses to match the roof as part of your base bid. A. The painting of the trusses is not part of the base bid. Painting is an alternate bid. Addendum #1 included a REVISED Form of Bid with two alternates.

END OF ADDENDUM