

# Fire Marshal's Office

125 N. Division St. Room 201  
Salisbury, Maryland 21803  
410-548-4994 phone  
410-548-4941 fax



# Wicomico County

Department of  
Planning, Zoning, &  
Community Development

## **FIRE ALARM SYSTEM CERTIFICATE OF INSPECTION**

1/12

Annual Certificate of Inspection       Non-Annual with a MAJOR violation

### **PROTECTED PROPERTY**

<b>Name:</b>	<b>Contact:</b>
<b>Address:</b>	<b>Phone #:</b>
<b>Owner:</b>	<b>Email:</b>
	<b>Phone #:</b>

### **FIRE ALARM COMPANY INFORMATION**

<b>Name:</b>	<b>Phone #:</b>
<b>Technician:</b>	<b>Date of Inspection:</b>

### **MONITORING INFORMATION**

<b>Is the system monitored off-site?</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>If yes, provide the following information:</b>	<b>Name:</b>	
<b>Location:</b>	<b>Phone #:</b>	

### **SYSTEM INFORMATION**

<b>Panel Manufacturer:</b>	<b>Model:</b>
<b>Location:</b>	<b>Remote Annunciator?</b> <input type="checkbox"/> Yes <input type="checkbox"/> No
<b>System Type:</b>	<input type="checkbox"/> Remote Station
<input type="checkbox"/> Central Station	<input type="checkbox"/> Local Alarm
<input type="checkbox"/> Proprietary	

**Major Violations Identified During Inspection:**     None     Checked Below

- |   |   |
|---|---|
| <input type="checkbox"/> System out of service / Impaired | <input type="checkbox"/> 10% or more initiating devices failed        |
| <input type="checkbox"/> FACP in Alarm / Trouble          | <input type="checkbox"/> 10% or more notification devices failed      |
| <input type="checkbox"/> System monitoring out of service | <input type="checkbox"/> required devices are missing / not installed |
| <input type="checkbox"/> Other – make comment             |   |

**Minor Violations Identified During Inspection:**     None     Checked Below

- |                               |                               |                               |                               |                               |
|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|
| <input type="checkbox"/> 1001 | <input type="checkbox"/> 1005 | <input type="checkbox"/> 1009 | <input type="checkbox"/> 1013 | <input type="checkbox"/> 1017 |
| <input type="checkbox"/> 1002 | <input type="checkbox"/> 1006 | <input type="checkbox"/> 1010 | <input type="checkbox"/> 1014 | <input type="checkbox"/> 1018 |
| <input type="checkbox"/> 1003 | <input type="checkbox"/> 1007 | <input type="checkbox"/> 1011 | <input type="checkbox"/> 1015 | <input type="checkbox"/> 1019 |
| <input type="checkbox"/> 1004 | <input type="checkbox"/> 1008 | <input type="checkbox"/> 1012 | <input type="checkbox"/> 1016 | <input type="checkbox"/> 1020 |

**Wicomico County Fire Marshal's Office**  
*Fire Alarm Certificate of Inspection (continued)*

**Comments / Violation Description**


**Minor Violations Identified During Inspection:**

- |  |  |
|--|--|
| 1001 - Battery / Secondary Power out-of-service                          | 1011 - Tamper Switch not Connected to FASS     |
| 1002 - A Battery out-of-date / Corroded                                  | 1012 - Manual Pull Station Obstructed          |
| 1003 - Smoke / Heat / Flame Detector Damaged                             | 1013 - Manual Pull Station Damaged             |
| 1004 - Smoke Detector too Close to Diffuser / Vent                       | 1014 - Bell, Horn / Strobes Damaged            |
| 1005 - Smoke Detector / Heat Detector not connected to FACP              | 1015 - Bell, Horn / Strobes Lacking Audibility |
| 1006 - Smoke Detector not A/C Powered with Battery Back-Up (Residential) | 1016 - Bell, Horn / Strobes Damaged / Missing  |
| 1007 - Inadequate Detector Coverage                                      | 1017 - Device Identification Lacking           |
| 1008 - Duct Detector Inoperative   | 1018 - Circuit Breaker to FACP no Lockout      |
| 1009 - Duct Detector Lacking System Shut-Down                            | 1019 - Supervisory Function Deficiency         |
| 1010 - Flow / Pressure Switch not Connected to FASS                      | 1020 - Other                                   |

**FM Office Use Only**

<input type="checkbox"/> No Major Violations Found	Data Entry Date: _____	Date Inspected: _____
<input type="checkbox"/> Major Violations Found: _____	Assigned To: _____	Date Corrected: _____
<input type="checkbox"/> Major Violations Verified: _____		