



Wicomico County Purchasing
125 N. Division St. Room B-3
Salisbury, MD 21801
Ph. 410-548-4805 Fax 410-334-3130
Email: purchasing@wicomicocounty.org

Addendum # 1 Replacement of Fencing for Two Tennis Courts at Winterplace Park

Date of Addendum: 04/23/19

NOTICE TO ALL BIDDERS AND PLANHOLDERS

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents. Vendors will take this Addendum into consideration when preparing and submitting a bid, and shall acknowledge receipt of this Addendum in the space provided in the Bid Documents.

BID SUBMITTAL DEADLINE

The bid submittal time has not been changed.

1.0 – QUESTIONS AND ANSWERS

The following questions and answers are provided as a matter of information to clarify issues raised about the Bid Documents.

Item	Questions and Answers
1.1	<p>Q. Please confirm that the County wants any missing braces & trusses replaced so that all terminal posts will be brace & trussed?</p> <p>A. Yes We want all the terminal post to have braces and trusses including the post that are currently missing them</p>
1.2	<p>Q. You are asking us to bid 1 3/4" x 9 ga. galvanized chain link fabric and an option for green vinyl chain link. Would you confirm that the green chain link should be 1 3/4" x 8 ga. 2B "fused & bonded" green vinyl (a 9ga. core wire)? This 8 ga. 2B green chain link would be equivalent to the 9 ga. galvanized.</p> <p>A. Yes. The chain link fabric should be 1 3/4" x 8 Ga 2B fused and bonded green vinyl.</p>

END OF ADDENDUM